

**CITY OF LA VISTA**  
**MAYOR AND CITY COUNCIL REPORT**  
**MARCH 6, 2012 AGENDA**

<b>Subject:</b>	<b>Type:</b>	<b>Submitted By:</b>
REHABILITATION/REPAIR GOLF COURSE PUMP	◆ RESOLUTION ORDINANCE RECEIVE/FILE	JOE SOUCIE PUBLIC WORKS DIRECTOR

**SYNOPSIS**

A resolution has been prepared authorizing Great Plains Well Service, LLC., to rehabilitate and repair the 50 hp irrigation pump at the Golf Course in an amount not to exceed \$7,230.00.

**FISCAL IMPACT**

The FY 2011/12 Golf Fund Budget provides funding for the proposed purchase.

**RECOMMENDATION**

Approval

**BACKGROUND**

The irrigation pumps at the Golf Course require periodic maintenance. The current pump is not broken, this is preventative maintenance task. Three quotes were submitted and Golf Superintendent Jeff Calentine is recommending Great Plains Well Service a the low qualified bidder.

Vendor	Quote
Great Plains Well Service, LLC.	\$7,230.00
Industrial Electric Motors	\$9,876.00
Sargent Drilling	\$11,126.00

RESOLUTION NO. \_\_\_\_\_

A RESOLUTION OF THE MAYOR AND CITY COUNCIL OF THE CITY OF LA VISTA, NEBRASKA, AUTHORIZING GREAT PLAINS WELL SERVICE, LLC TO REHABILITATE AND REPAIR THE 50 HP IRRIGATION PUMP AT THE GOLF COURSE IN AN AMOUNT NOT TO EXCEED \$7,230.00.

WHEREAS, the City Council of the City of La Vista has determined that rehabilitation and repair of the irrigation pump at the Golf Course is necessary; and

WHEREAS, the FY 11/12 Golf Fund Budget contains funding for this project; and

WHEREAS, Great Plains Well Service, LLC submitted the lowest qualified bid; and

WHEREAS Subsection (C) (9) of Section 31.23 of the La Vista Municipal Code requires that the City Administrator secures Council approval prior to authorizing any purchase over \$5,000.00.

NOW, THEREFORE, BE IT RESOLVED, that the Mayor and City Council of La Vista, Nebraska authorize Great Plains Well Service, LLC to rehabilitate and repair the 50 HP irrigation pump at the golf course in an amount not to exceed \$7,230.00.

PASSED AND APPROVED THIS 6TH DAY OF MARCH, 2012.

CITY OF LA VISTA

---

Douglas Kindig, Mayor

ATTEST:

---

Pamela A. Buethe, CMC  
City Clerk

# INDUSTRIAL ELECTRIC MOTORS

ESTABLISHED 1922

"MIDWEST'S POWER

"REPAIR SHOP"

9770 S 142nd St  
Omaha NE 68138  
Phone (402) 331-0700  
Fax (402) 331-0704

An  Group Company

February 22, 2012

Jeff Calentine  
City Of La Vista  
8116 Park View Blvd.  
La Vista, NE 68128

RE: Breakdown Of Irrigation Pump Repairs

Mr. Calentine,

Industrial Electric Motors is pleased to present this estimate for repair of your two irrigation pumps and motors. This estimate is based on our site visit with you on April 20, 2011. The scope of our services for this project will include the following.

- Removal and installation of pumps and motors
- Replacing motor inboard and outboard bearings
- Balancing motor rotors
- Dip and baking motor windings
- Replacing pump seals and bushings

The 15 HP pump and motor repair **\$ 3,487.00**. Crane charge **\$ 1,500.00**.

The 50 HP pump and motor repair **\$ 8,376.00**. Crane charge **\$ 1,500.00**.

Any shaft or impeller replacement if needed after disassembly and inspection would be an extra charge.

We appreciate the opportunity to present this estimate and look forward to assisting you in the successful completion of this project. We would be glad to discuss any questions you may have regarding this proposal.

Sincerely,

Edward J. Alex

*Ryan Drury*  
**INDUSTRIAL ENGINEERING**  
**COMPLETE MUNICIPAL AND INDUSTRIAL**  
**PUMPS AND WELL SERVICE**

PO Box 367  
 Geneva, NE 68361-0367

846 South 13<sup>th</sup> St Phone: (402) 759-3902  
 1-888-496-3902

January 30, 2012

The Sprinkler Co.  
 84420 562<sup>nd</sup> Ave.  
 Stanton, NE 68779

Attn: Dick Wright

RE: La Vista Falls Golf

Irrigation Booster Pump #1 *500 H/P*

Labor to pull and set pump	\$2,000.00
15'- 6" column pipe complete	\$1,714.00
1- 6 stage 10SC bowl assembly (600 gpm @ 260 TDH)	\$6,662.00
Rework discharge head	\$750.00
<b>Total (does not include applicable sales tax)</b>	<b>\$11,126.00</b>

Irrigation Booster Pump #2

Labor to pull and set pump	\$2,000.00
15'- 4" column pipe complete	\$1,508.00
1- 6 stage 9 WAHC bowl assembly	\$7,217.00
Rework discharge head	\$750.00
<b>Total (does not include applicable sales tax)</b>	<b>\$11,475.00</b>

Note: Any electric motor work would be extra!

If you have any questions please call the office at (402) 759-3902.

Thank You,



Doug Yantzie,  
 Municipal Manager

DY/dh